

CROSS TIMBERS WATER SUPPLY CORPORATION

PUBLIC NOTICE

Date: 03/23/2021

To: All Cross Timbers Water Supply Members

Triggered Source Monitoring and Reporting Violation, Groundwater Rule


Cross Timbers Water Supply Corporation (Public Water System ID # 0610020), failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the groundwater system during the month of September 2019. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine sample total coliform result in our distribution system, our water system is required to submit one source sample for every active groundwater well source. Failure to collect all required samples is a violation of the monitoring requirements and we are required to notify the members of this violation.

What Should I Do? There is nothing the customer/members needs to do currently.

What is being done? A discrepancy was found on the number of samples CTWS submitted to Texas Commission on Environmental Quality. Once notified CTWS submitted new samples within 24 hours and those new samples came back with no positive results. CTWS misunderstood on the number of samples needed from the well site. CTWS collected the required samples from the well and submitted them to TCEQ. Under the TCEQ rules we are required to inform you of this violation. There was no impact on your water quality.

Chad Wolf



General Manager